



GE VERNOVA

MVAA

Technical Manual
Tripping and Auxiliary Relay

Publication Reference: R8009H

HANDLING OF ELECTRONIC EQUIPMENT

A person's normal movements can easily generate electrostatic potentials of several thousand volts. Discharge of these voltages into semiconductor devices when handling circuits can cause serious damage, which often may not be immediately apparent but the reliability of the circuit will have been reduced.

The electronic circuits of GE Vernova products are immune to the relevant levels of electrostatic discharge when housed in their cases. Do not expose them to the risk of damage by withdrawing modules unnecessarily.

Each module incorporates the highest practicable protection for its semiconductor devices. However, if it becomes necessary to withdraw a module, the following precautions should be taken to preserve the high reliability and long life for which the equipment has been designed and manufactured.

- 1 Before removing a module, ensure that you are at the same electrostatic potential as the equipment by touching the case.
- 2 Handle the module by its front-plate, frame, or edges of the printed circuit board. Avoid touching the electronic components, printed circuit track or connectors.
- 3 Do not pass the module to any person without first ensuring that you are both at the same electrostatic potential. Shaking hands achieves equipotential.
- 4 Place the module on an antistatic surface, or on a conducting surface which is at the same potential as yourself.
- 5 Store or transport the module in a conductive bag.

More information on safe working procedures for all electronic equipment can be found in BS5783 and IEC 60147-0F.

If you are making measurements on the internal electronic circuitry of an equipment in service, it is preferable that you are earthed to the case with a conductive wrist strap.

Wrist straps should have a resistance to ground between 500k – 10M ohms. If a wrist strap is not available you should maintain regular contact with the case to prevent the build up of static. Instrumentation which may be used for making measurements should be earthed to the case whenever possible.

GE Vernova strongly recommends that detailed investigations on the electronic circuitry, or modification work, should be carried out in a Special Handling Area such as described in BS5783 or IEC 60147-0F.

TYPES: MVAA 11
 MVAA 12
 MVAA 13
 MVAA 14
 MVAA 15
 MVAA 16

CONTENTS

	SAFETY SECTION	5
1	INSTALLATION	9
1.1	General	9
1.2	Unpacking	9
1.3	Storage	9
1.4	Site	9
2.	COMMISSIONING	10
2.1	General	10
2.2	Wiring	10
2.3	Commissioning preliminaries	10
2.4	Insulation	10
2.5	Operation	11
3.	MAINTENANCE	11
4.	MECHANICAL SETTINGS	11
4.1	General	11
4.2	Contact settings	12
4.2.1	Relays with armature operated contacts.	12
4.2.2	Relays with mechanically operated contacts	13
4.2.3	Relays with mechanically latched contacts	13
4.3	Mechanical settings related to the latch for MVAA 13, 14 and 15	14
4.4	Electrical reset mechanism	14
4.5	Mechanical flag settings	15
4.5.1	Settings for self reset units	15
4.5.2	Settings for hand and self reset units	15
4.5.3	Settings for hand reset and electrically reset units: MVAA 13, 14 and 15:	15
4.6	Settings for reset levers on hand reset and hand/electrically reset units	15
5.	PROBLEM ANALYSIS	15
5.1	Failure to operate/reset	15
5.2	Excessive current taken by relay:	16
5.3	Output contacts not changing state:	16
6.	SPARES	16
7.	COMMISSIONING TEST RECORD	17
	REPAIR FORM	19

SAFETY SECTION

This Safety Section should be read before commencing any work on the equipment.

Health and safety

The information in the Safety Section of the product documentation is intended to ensure that products are properly installed and handled in order to maintain them in a safe condition. It is assumed that everyone who will be associated with the equipment will be familiar with the contents of the Safety Section.

Explanation of symbols and labels

The meaning of symbols and labels which may be used on the equipment or in the product documentation, is given below.

	
Caution: refer to product documentation	Caution: risk of electric shock
	Protective/safety *earth terminal
	Functional *earth terminal. Note: this symbol may also be used for a protective/safety earth terminal if that terminal is part of a terminal block or sub-assembly eg. power supply.

*Note: The term earth used throughout the product documentation is the direct equivalent of the North American term ground.

Installing, Commissioning and Servicing



Equipment connections

Personnel undertaking installation, commissioning or servicing work on this equipment should be aware of the correct working procedures to ensure safety. The product documentation should be consulted before installing, commissioning or servicing the equipment.

Terminals exposed during installation, commissioning and maintenance may present a hazardous voltage unless the equipment is electrically isolated.

If there is unlocked access to the rear of the equipment, care should be taken by all personnel to avoid electric shock or energy hazards.

Voltage and current connections should be made using insulated crimp terminations to ensure that terminal block insulation requirements are maintained for safety. To ensure that wires are correctly terminated, the correct crimp terminal and tool for the wire size should be used.

Before energising the equipment it must be earthed using the protective earth terminal, or the appropriate termination of the supply plug in the case of plug connected equipment. Omitting or disconnecting the equipment earth may cause a safety hazard.

The recommended minimum earth wire size is 2.5 mm², unless otherwise stated in the technical data section of the product documentation.

Before energising the equipment, the following should be checked:

- Voltage rating and polarity;
- CT circuit rating and integrity of connections;
- Protective fuse rating;
- Integrity of earth connection (*where applicable*)

Equipment operating conditions

The equipment should be operated within the specified electrical and environmental limits.

Current transformer circuits



Do not open the secondary circuit of a live CT since the high voltage produced may be lethal to personnel and could damage insulation.

External resistors



Where external resistors are fitted to relays, these may present a risk of electric shock or burns, if touched.

Battery replacement



Where internal batteries are fitted they should be replaced with the recommended type and be installed with the correct polarity, to avoid possible damage to the equipment.

Insulation and dielectric strength testing



Insulation testing may leave capacitors charged up to a hazardous voltage. At the end of each part of the test, the voltage should be gradually reduced to zero, to discharge capacitors, before the test leads are disconnected.

Insertion of modules and pcb cards



These must not be inserted into or withdrawn from equipment whilst it is energised, since this may result in damage.

Fibre optic communication



Where fibre optic communication devices are fitted, these should not be viewed directly. Optical power meters should be used to determine the operation or signal level of the device.

Older Products

Electrical adjustments



Equipments which require direct physical adjustments to their operating mechanism to change current or voltage settings, should have the electrical power removed before making the change, to avoid any risk of electric shock.

Mechanical adjustments



The electrical power to the relay contacts should be removed before checking any mechanical settings, to avoid any risk of electric shock.

Draw out case relays



Removal of the cover on equipment incorporating electromechanical operating elements, may expose hazardous live parts such as relay contacts.

Insertion and withdrawal of extender cards



When using an extender card, this should not be inserted or withdrawn from the equipment whilst it is energised. This is to avoid possible shock or damage hazards. Hazardous live voltages may be accessible on the extender card.

Insertion and withdrawal of heavy current test plugs



When using a heavy current test plug, CT shorting links must be in place before insertion or removal, to avoid potentially lethal voltages.



Decommissioning and Disposal

Decommissioning: The auxiliary supply circuit in the relay may include capacitors across the supply or to earth. To avoid electric shock or energy hazards, after completely isolating the supplies to the relay (both poles of any dc supply), the capacitors should be safely discharged via the external terminals prior to decommissioning.

Disposal: It is recommended that incineration and disposal to water courses is avoided. The product should be disposed of in a safe manner. Any products containing batteries should have them removed before disposal, taking precautions to avoid short circuits. Particular regulations within the country of operation, may apply to the disposal of lithium batteries.

Technical Specifications

Protective fuse rating

The recommended maximum rating of the external protective fuse for this equipment is 16A, Red Spot type or equivalent, unless otherwise stated in the technical data section of the product documentation.

Insulation class:	IEC 61010-1: 1990/A2: 1995	This equipment requires a protective (safety) earth connection to ensure user safety.
	Class I	
	EN 61010-1: 1993/A2: 1995	
	Class I	
Installation Category (Overvoltage):	IEC 61010-1: 1990/A2: 1995	Distribution level, fixed installation. Equipment in this category is qualification tested at 5kV peak, 1.2/50μs, 500Ω, 0.5J, between all supply circuits and earth and also between independent circuits.
	Category III	
	EN 61010-1: 1993/A2: 1995	
	Category III	
Environment:	IEC 61010-1:1990/A2: 1995	Compliance is demonstrated by reference to generic safety standards.
	Pollution degree 2	
	EN 61010-1: 1993/A2: 1995	
	Pollution degree 2	
Product safety: CE	73/23/EEC	Compliance with the European Commission Low Voltage Directive.
	EN 61010-1: 1993/A2: 1995	Compliance is demonstrated by reference to generic safety standards.
	EN 60950: 1992/A11: 1997	

Section 1. INSTALLATION

1.1 General

Protective relays, although generally of robust construction, require careful treatment prior to installation and a wise selection of site. By observing a few simple rules the possibility of premature failure is eliminated and a high degree of performance can be expected.

The relays are either dispatched individually or as part of a panel/rack mounted assembly in cartons specifically designed to protect them from damage.

Relays should be examined immediately they are received to ensure that no damage has been sustained in transit. If damage due to rough handling is evident, a claim should be made to the transport company concerned immediately, and the nearest GE Vernova representative should be promptly notified. Relays which are supplied unmounted and not intended for immediate installation should be returned to their protective polythene bags.

1.2 Unpacking

Care must be taken when unpacking and installing the relays so that none of the parts is damaged or their settings altered, and must at all times be handled by skilled persons only.

Relays should be examined for any wedges, clamps, or rubber bands necessary to secure moving parts to prevent damage during transit and these should be removed after installation and before commissioning.

Relays which have been removed from their cases should not be left in situations where they are exposed to dust or damp. This particularly applies to installations which are being carried out at the same time as constructional work.

1.3 Storage

If relays are not installed immediately upon receipt they should be stored in a place free from dust and moisture in their original cartons and where de-humidifier bags have been included in the packing they should be retained. The action of the dehumidifier crystals will be impaired if the bag has been exposed to ambient conditions and may be restored by gently heating the bag for about an hour, prior to replacing it in the carton.

Dust which collects on a carton may, on subsequent unpacking, find its way into the relay; in damp conditions the carton and packing may become impregnated with moisture and the de-humidifying agent will lose its efficiency.

The storage temperature range is -25°C to $+70^{\circ}\text{C}$.

1.4 Site

The installation should be clean, dry and reasonably free from dust and excessive vibration. The site should preferably be well illuminated to facilitate inspection.

An outline diagram is normally supplied showing panel cut-outs and hole centres. For individually mounted relays these dimensions will also be found in publication R6009.

Publication R7012 is a Parts Catalogue and Assembly Instructions. This document will be useful when individual relays are to be assembled as a composite rack or panel mounted assembly.

Publication R6001 is a leaflet on the MIDOS modular integrated drawout system of protective relays.

Publication R6014 is a list of recommended suppliers for the pre-insulated connectors.

Section 2. COMMISSIONING

2.1 General

Before leaving the factory all relays are accurately adjusted, tested and carefully packed. Hence there should be no need for any re-adjustment on commissioning.

Moving parts are held in position during transit by rubber bands and packing. These should be removed carefully.

2.2 Wiring

Check that the rating information is correct for the system.

Check all wiring connections to the relay, including the case earthing connection above the terminal block. It is especially important that dc supplies and magnetic blowout contacts are wired with the correct polarity. The relay diagram number appears inside the case.

2.3 Commissioning preliminaries

To gain access to the relay first loosen the captive cover screws. Then carefully remove the cover from the case.

The module can then be removed from the case by grasping the handles at the top and bottom of the front plate and pulling forwards.

Care must be taken to ensure that mechanical settings of the element are not disturbed.

Carefully remove the rubber band securing the flag mechanism.

Check that the bottom end of the contact operating card has not been dislodged from the slot in the armature extension and that the ends of the push rods are located in the holes in the contact springs.

Carefully actuate the armature of each unit in turn with a small screwdriver/probe.

Note: Immediately after the point where any make contacts just close there is a further small movement of the armature. This ensures that contact follow through and wiping action is present. Repeat similarly with break contacts on armature release.

On units fitted with hand reset flag indicators, check that the flag is free to fall before, or just as, any make contacts close.

Replace the module in the case and refit the cover. Make sure that the reset mechanism in the cover is correctly located with respect to the relay element, and that the flag (or mechanism) can be reset.

2.4 Insulation

The relay, and its associated wiring, may be insulation tested between:

- all electrically isolated circuits
- all circuits and earth.

An electronic or brushless insulation tester should be used, having a dc voltage not exceeding 1000V. Accessible terminals of the same circuit should first be strapped together. Deliberate circuit earthing links, removed for the tests, subsequently must be replaced.

2.5 Operation

Check operation of electrical reset by energising the relay with 80% of the rated supply voltage. The appropriate terminals should be identified from the internal wiring diagram normally supplied.

Disconnect external wiring from these terminals to allow application of the test supply.

The relays should switch cleanly with one movement.

The rated voltages are marked on either the lower hand strip or front plate.

Restore any external wiring connections that may have been disturbed during the above tests.

Section 3. MAINTENANCE

Periodic maintenance is not necessary. However, periodic inspection and test is recommended. This should be carried out every 12 months or more often if the relay is operated frequently or is mounted in poor environmental conditions.

Repeat check 2.3 with emphasis on contact wear and condition. Mechanical settings may be checked against those shown in Section 4.

Tests 2.4 and 2.5 should be carried out to prove operation.

Section 4. MECHANICAL SETTINGS

4.1 General

Armature gap measurements should be made with the top of the feeler gauge level with the centre line of the core.

Contact pressures are measured with a gramme gauge at the contact tips.

In general contact gaps and follow through are defined by quoting an armature gap at which the tips should be just closed or just open.

The relay contact state is always defined with the relay in the unenergised position, unless otherwise specified on the appropriate circuit diagram.

Contact Type	Symbol used on diagrams	
	Normal duty	Heavy Duty
Make (Normally open)	M	Z
Break (Normally closed)	B	Y
Break before make (Changeover)	BBM	-

- 4.1.1 With the armature closed the clearance between the back of the armature and the back stop should be 0.003"/0.008".
- 4.1.2 Nominal armature gap open 0.050"/0.060" for all types except MVAA 16 which has a nominal armature gap of 0.025".

4.2 Contact settings

- 4.2.1 Relays with armature operated contacts.

Types MVAA 11 self reset, MVAA 12 self reset contacts only. For hand reset contacts, refer to Section 4.2.2.

- 4.2.1.1 Contact settings for:

Normal/heavy duty make and break contacts.

With the armature closed onto a 0.011" feeler gauge the make contacts should be closed, but should be open using a 0.013" feeler gauge.

With the armature closed onto a 0.027" feeler gauge the break contact should be open, but should be closed using a 0.029" feeler gauge.

Force to just close the make contacts: 20/25 grams.

Force to just open the break contacts: 18/23 grams.

- 4.2.1.2 Contact settings for:

Normal duty break before make contacts.

With the armature closed onto a 0.011" feeler gauge the make contact should be closed, but should be open using a 0.013" feeler gauge.

With the armature closed onto a 0.028" feeler gauge the break contact should be open, but should be closed using a 0.031" feeler gauge.

Force to just close the make contacts: 20/25 grams.

The force is measured at the outer tip.

The force to just open the break contacts: 18/23 grams.

The force is measured at the inner tip.

- 4.2.1.3 Contact settings for:

MVAA 16 normal duty make and break contacts.

With the armature closed onto a 0.012" feeler gauge, the make contacts should be closed, but should be open with a 0.015" feeler gauge.

With the armature closed onto a 0.012" feeler gauge the break contacts should be open, but should be closed with a 0.015" feeler gauge.

With the armature closed onto a 0.007" feeler gauge the internal economising break contact (top left hand) should be open, but should be closed with a 0.009" feeler gauge.

Contact gap: 0.020"/0.025" output contacts

0.010"/0.015" internal economising contact

Force to just close the make contacts: 18/22 grams.

Force to just open the break contacts: 13/16 grams.

4.2.2 Relays with mechanically operated contacts

Types MVAA 12 hand reset contacts only. For self reset contacts refer to Section 4.2.1.

4.2.2.1 Contact settings for:

Normal duty make and break long hand reset contacts.

The following settings are with the mechanism operated (flag down).

Contact gap: (make) 0.07"/0.1"

(break) 0.07"/0.08" – with mechanism operated (flag down)

with the mechanism operated:

Force to just open the make contact: 25/35 grams

Force to just close the break contact: 35/40 grams

The gap between the top of the armature and the make moving contact should be 0.130" minimum when the flag is down.

Relays with four pairs of hand reset contacts:

It will be necessary to remove the force of the upper contacts from the lower set. This is carried out by carefully lifting the pushrod upwards and then measuring the appropriate contact force.

Also with the flag down the force to just move the armature off the backstop should be 60/80 grams. This force is measured at the end of the armature and is adjusted by the screw which is located between the contact blades near to the contact blocks.

4.2.2.2 Contact setting for:

Normal duty make and break short hand reset contacts.

The following settings are with the mechanism operated (flag down).

Contact gaps 0.070"/0.080"

Force to just close the make contacts: 18/23 grams.

Force to just open the break contacts: 20/25 grams.

4.2.3 Relays with mechanically latched contacts

Types MVAA 13, 14 and 15.

4.2.3.1 Contact settings for:

Normal/heavy duty make and break contacts with the armature closed onto a 0.018" feeler gauge, the make contacts should be closed, but should be open with a 0.022" feeler gauge.

When the armature has settled back on the catch the break contact gap should be 0.060"/0.070".

Force to just close the make contacts: 20/25 grams.

Force to just open the break contacts: 18/23 grams.

4.2.3.2 Contact settings for:

Normal duty break before make contacts.

With the armature closed onto a 0.018" feeler gauge the make contact should be closed, but should be open with a 0.022" feeler gauge.

With the armature closed onto a 0.021" feeler gauge the break contact should be open, but should be closed using a 0.025" feeler gauge.

Force to just close the make contact : 20/25 grams.

The force is measured at the outer tip.

Force to just open the break contact : 18/23 grams.

The force is measured at the inner tip.

4.2.3.3 Contact setting for:

Cut-off contact - lower left hand contact.

First set the lower lug on the armature extension so that the top of the roller is level with the top of the plastic catch when the relay is in the operated position.

Remove the operating wire from the plastic block on the moving contact.

Set the contact gap to 0.045"/0.055".

Force to just close the make contact 12/15 grams.

Reposition the operating wire which should locate freely in the hole in the plastic block on the moving contact blade. If necessary bend the wire to suit.

4.3 Mechanical settings related to the latch for MVAA 13, 14 and 15

The upper limiting lug should be clear of the cross roller and armature backstop in all positions.

Care should be taken to ensure that the upper lug still prevents the cross roller from riding up and over the armature extension.

With the armature closed the force to lift the cross roller above the latch should be 40/50 grams.

With the armature closed onto a 0.003" feeler gauge the cross roller should pass clear of the plastic catch, but with a 0.006" feeler gauge the roller should not clear the catch. To achieve this the armature extension should be bent. The upper face of the plastic catch should remain tangential to a circle centred on the armature hinge. The armature should return freely to the fully open position when partly closed and released and the reset arm should fall freely to the fully operated position when partly reset and released.

4.4 Electrical reset mechanism

MVAA 14 and 15

With the unit de-energised the lever arm should rest on the frame with the control spring just touching.

When the reset armature is closed onto a 0.01" feeler gauge it should reset the main element, but not reset with a 0.02" feeler gauge.

If the reset mechanism has been moved or changed, it may be necessary to adjust the position of the reset electromagnet by means of the mounting screws which are located in slotted holes.

4.5 Mechanical flag settings

4.5.1 Settings for self reset units

MVAA 11

With the armature closed onto a 0.013" feeler gauge the flag should be free to fall, but should not fall using a 0.018" feeler gauge. Adjustment is made to the catch spring on the flag.

4.5.2 Settings for hand and self reset units

MVAA 12

With the armature closed onto a 0.005" feeler gauge the flag should be free to fall, but should remain unoperated with a 0.01" feeler gauge. Adjustment should be made equally to both flag catch springs on the flag.

With the armature held closed the force to raise the flag, such that the roller just touches the long contacts is between 60 - 80 grams. This force is measured at the reset tab on the flag and adjustment is by means of the spring on flag side arms.

4.5.3 Settings for hand reset and electrically reset units: MVAA 13, 14 and 15:

With the armature closed onto a 0.023" feeler gauge the flag shall be free to fall, but should remain unoperated with a 0.028" feeler gauge. Adjustment is made to the flag catch spring on the flag.

4.6 Settings for reset levers on hand reset and hand/electrically reset units

MVAA 13, 15

The distance between the reset lever and the top of the reset arm should be 0.250". This is measured above the roller pivot and is adjusted by bending the reset lever.

Section 5. PROBLEM ANALYSIS

5.1 Failure to operate/reset

Check diagram for correct input connections.

Check rated voltage; this is marked on the front of the module.

Ensure the power supply is capable of supplying the necessary power.

With MVAA13, 14 and 15, check that the relays are not latched in the operated position.

Some relays may be fitted with cut-off contacts - refer to diagram.

Flag spring may be jammed between armature and core face, preventing armature closure.

Check internal wiring.

Check continuity - result open circuit:

- coil open circuit.
- cut-off contact in series with coil open circuit.
- internal wiring damaged.
- diode bridge damaged.
- series resistor open circuit.

Check continuity - result short circuit:

– diode bridge damaged - relay takes excessive current.

5.2 Excessive current taken by relay:

Diode bridge damaged.

Incorrect voltage applied.

External resistors not connected.

Internal resistors short circuited.

5.3 Output contacts not changing state:

Operating card/push rod not in position.

Check output terminals with reference to diagram.

Internal wiring damaged.

Contamination of contacts.

Contacts should be cleaned with the burnishing tool, supplied in relay tool kits.

On no account should knives, files or abrasive materials be used.

Check mechanical settings as per Section 4.

Section 6. SPARES

When ordering spares, quote the full relay model number and any component references numbers, or briefly describe the parts required.

Repairs

Should the need arise for the equipment to be returned to GE Vernova for repair, then the form at the back of this manual should be completed and sent with the equipment together with a copy of any commissioning test results.

Section 7. COMMISSIONING TEST RECORD

Auxiliary Relay Type MVAA

Date _____

Station _____

Circuit _____

Model No. _____

Serial No. _____

Wiring Diag. No. _____

Nominal voltage rating range _____ / _____ AC/DC

1. Outgoing contact availability

Device Ref.	Number and type of contact		
	Make (Open)*	Break (Closed)	Change-over

* Note: Contact state with the unit(s) de-energised

2. Relay visually inspected:

a) For freedom from damage in transit ☐ (tick)

b) That contact follow-through and pressures appear satisfactory ☐ (tick)

3. Contact wiring check

Outgoing contact wiring checked to wiring diagram ☐ (tick)

4. Electrical operation

Satisfactory operation obtained at 80% V of the lower voltage of the relays nominal voltage rating range

☐ DC ☐ Hz (delete)

Operation ☐ (tick)

Electrical reset ☐ (delete as necessary)

5. Operation (Flag) Indicators

☐ Yes ☐ No (delete)

Satisfactory operation obtained ☐ (tick)

6. Hand reset mechanism

☐ Yes (delete if not applicable)

The following functions satisfactorily with the cover in position:-

Flag reset ☐ Contact Reset ☐ Flag contact reset (combined) ☐

7. Remarks

Commissioning Engineer

Customer Witness

Date

Date

5. Return Packaging Standards (ALL PRODUCTS)

1. Please ensure the device is clean, no sharp edges are exposed and the device is in a suitable condition to be handled.
2. Relay's returned without cases should be placed in to Anti-Static Bags and sealed to protect hyper-sensitive components.



3. A suitable size box should be used, with packing material at the bottom, the device placed into box with sufficient gaps to fill with packing material around each side and on the top, extra packaging material placed around the relay.



4. Please include a copy of the completed RMA form then close the lid and seal with packaging tape.



5. The relay should then be secondary packed if being exported, the primary packed box should be placed into an oversized box with packaging material surrounding the primary packed box and then sealed.



GE VERNOVA