



CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 050302 - E226982

ISSUE DATE: May 3, 2002

Page 1 of 1

Issued to: General Electric Co. PD Commercial Transformer
7000 Bert Kouns Ind Loop
Shreveport, LA 71129

Report Reference: E226982 - April 19, 2002

This is to Certify that representative samples of: **PRODUCT COVERED:**


Transformers, Distribution, Liquid-Filled Type - Over 600 Volts, Type Compad.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: United States Standard - UL 1562

Additional Information: **RATINGS:**
Maximum System Voltage, kV 69
Maximum BIL, kV 350
Maximum KVA 100,000(100 MVA)

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer: 
Paul Barnhart
Underwriters Laboratories Inc.

Review Engineer: 
Kenneth McKinney
Underwriters Laboratories Inc.