Grid Solutions

MODEL 603-500T & 603D-500T

Current Transformers Split Core

Window Size 2.00" x 1.00", 2.00"x 2.00"



603D-500T

603-500T

Application

For energy management systems and instrumentation equipment having a no return high input impedance, eg. 14 K ohms minimum.

Frequency

50-400 Hz.

Insulation Level

0.6kV, 10 kV BIL full wave.

Models 603-500T & 603D-500T

| CATALOG NUMBER | CURRENT RATIO | BURDEN VA | ACCURACY AT 60 Hz |
|-------------------|------------------|-----------|----------------------|
| 603-101-1 | 100:1 | - | - |
| 603-201-1 | 200:1 | - | - |
| 603-301-1 | 300:1 | - | - |
| 603D-101-1 | 100:1 | - | - |
| 603D-201-1 | 200:1 | - | - |
| 603D-301-1 | 300:1 | - | - |
| 603D-401-1 | 400:1 | - | - |
| 603D-500T | 500 Turns | - | - |
| 603D-501-1 | 500:1 | - | - |
| 603D-601-1 | 600:1 | - | - |


Continuous Thermal Current Rating Factor


Model 603:

350 A at 30°C. amb., 260 A at 55°C. amb.

Flexible leads UL 1015, 105°C, CSA approved, #22 AWG, 24" long unless otherwise specified.

Approximate Weight:









Models 603-500T & 603D-500T Split Core

These transformers are designed for assembly to an existing electrical installation without the need for dismantling the primary bus or cables.


These transformers is intended for use with high input impedance devices that require signal voltages up to 5 VAC.

The output can be rectified and filtered for devices requiring DC input. The non-linearity and voltage drop of the rectifiers and filters must be considered in the choice of the loading impedance.

Caution:

Proper safety precautions must be followed during installation by a trained electrician. Never install while bus is energized.

The current transformer must have its secondary terminals short circuited or the burden connected, before energizing the primary circuit.



For more information, visit **gevernova.com/grid-solutions**

X2

X1

Instrument Transformers LLC reserve the rightto change specifications of described products at any time without notice and without obligation to notify any person of such changes.

© 2025 GE Vernova and/or its affiliates. All rights reserved. GE and the GE Monogram are trademarks of General Electric Company used under trademark license.

