MODEL JVW-150

Outdoor Voltage Transformer

60 Hz, 12,000 V to 24,000 V, BIL 150 kV



JVW-150 Single-bushing Model

Application

Designed for outdoor service; the model JVW-150 is a metering voltage transformer specifically designed to meet the requirements of 25 kV outdoor metering applications.

Thermal Rating

Weight - Shipping/Net

(approximate, in pounds)
Transformer......155/140

Reference Drawings

Accuracy Curve at	
120 Secondary Volts, 60 Hz	9932600220
Excitation Curve	9932600167
Outline Drawings:	
Two-Bushing Model	9935492
Single-Bushing Model	9935491
Wiring Diagram	refer to page 42, figure 5

Accessories - Catalog Number

Mounting Hardware:

"L" Mounting Brackets	.8944634002
Channel Bracket	5466227001
Suspension Hooks	8944630001
Secondary Conduit Box	.9689970001

JVW-150


LINE TO	LINE-TO-LINE CIRCUIT CIRCUIT VOLTAGE FOR PERMISSIBLE PRIMARY CONNECTION			ACCURACY CLASSIFICATION 60 Hz						
				TRANSFORMER RATING ⁽¹⁾		BURDEN PER ANSI		BURDEN IMPEDANCE	CATALOG NUMBER	
Δ	Y	Y ONLY	GY ONLY (1)	PRIMARY VOLTAGE	RATIO	OPERATED AT RATED VOLTAGE	OPERATED AT 58 % OF RATED VOLTAGE	AS AT RATED VOLTAGE BUT OPERATED AT 58 % RATED VOLTAGE (3)	SINGLE BUSHING MODEL	TWO BUSHING MODEL
			12,000 (4)	12,000	100:1	0.3 W, X, M, Y	0.3 W, X; 1.2 M, Y	0.3 W', X', M', Y'	766X034001	
			14,400 (5)	14,400	120:1	0.3 W, X, M, Y	0.3 W, X; 1.2 M, Y	0.3 W', X', M', Y'	766X034002	766X034006
18,000 ⁽²⁾	18,000 ⁽²⁾	18,000 ⁽²⁾		18,000	150:1	0.3 W, X, M, Y	0.3 W, X; 1.2 M, Y	0.3 W, X, M, Y		766X034003
24,000 (2)	24,000 (2)	24,000 (2)		24,000	200:1	0.3 W, X, M, Y	0.3 W, X; 1.2 M, Y	0.3 W', X', M', Y'		766X034004

Notes:

- (1) These single bushing transformers are suitable for application to grounded systems, for operation line-to-ground only. They will operate without damage connected lineto-ground at 1.40 times the transformer-rated voltage for one minute. If it should become necessary to apply these grounded wye voltage transformers to an ungrounded system, refer to the nearest General Electric Sales Office for a system analysis study.
- (2) These two-bushing transformers are designed for operation line-to-line. They may also be operated line-to-ground or line-to-neutral at reduced voltage (58% of rated voltage).
- (3) The prime symbol (') is used to signify that these burdens do not correspond to standard ANSI definitions.
- (4) 20,780 in Y configuration
- (5) 24,940 in Y configuration.



Model JVW-150



Mechanical Dimensions (two-bushing model shown)

Construction and Insulation

Please refer to General Product Information, item 1.4.

Core

Please refer to General Product Information, item 2.4.

Coils

Please refer to General Product Information, item 3.2

Primary Terminals

Please refer to General Product Information, item 4.6.

Secondary Terminals

Please refer to General Product Information, item 4.18.

Ground Terminal

Please refer to General Product Information, item 4.23.

Conduit Box

Please refer to General Product Information, item 12.1.

Polarity

Please refer to General Product Information, item 7.1.

Baseplate and Mounting

Please refer to General Product Information, items 5.3, 5.15 and the Application Information Section of this volume.

Nameplate

Please refer to General Product Information, item 6.2.

Rating Identification

Please refer to General Product Information, item 13.1.

Maintenance

Please refer to General Product Information, item 10.1 and pages 24-27.

Note:

1. Voltage transformers of this type are available for use in 50 Hz applications in many ratings. However, Industry Standard IEEE 57.13 to which we test transformers does not apply at 50 Hz. Customers who order voltage transformers for 50 Hz application should provide an accuracy specification including Burden VA and Power Factor. If an accuracy specification is not made available, the transformer(s) will be tested at 60 Hz with test burdens as defined in IEEE 57.13 for 60 Hz applications.

For more information, visit **gevernova.com/grid-solutions**

GE Vernova reserves the right to make changes to specifications of described products at any time without notice and without obligation to notify any person of such changes.

© 2025 GE Vernova and/or its affiliates. All rights reserved. GE and the GE Monogram are trademarks of General Electric Company used under trademark license.

